

Roddy Creek and Avola Creek Watershed Source Protection
Direct Impacts from Forestry Practices on Licensed Water Sources

William Shulba, P.Geo
Watershed Geoscientist

TECHNICAL LETTER
Independent Assessment
July 2022

The Issue

As of 2021 there has been impacts on drinking water license number F043942 near Avola, BC. William Shulba, P. Geo was made aware of direct impacts from forestry operations on this water source in September 2021.

On October 18, 2021, William Shulba made a site visit to the subject property that was guided by the landowner, Nels Olson. At that time, there were active impacts from forestry operations, mainly road building, that was transporting visible sediment to the licensed water works and generating significant drinking water impacts in the point of diversion and licensed linear works, (line ID: 556501469). At that time, the main crossing of Roddy Creek was not completed and the culvert was not installed. Attached is a photo log demonstrating visual impacts on the landowners water system.

The License

The water license is on a private domestic property near the town of Avola, BC an unincorporated community located in the Thompson-Nicola Regional District of British Columbia. The civic address is 4137 Messiter Station Rd, legal description DISTRICT LOT 4043 KAMLOOPS DIVISION YALE DISTRICT, parcel ID 013-222-449 approximately 18 acres, RL-1 zoning, with primary use of domestic homesteading that includes small scale agriculture.

The water license F043942, with a date of precedent of August 17, 1959, approximately 63 years on Roddy Creek for 4,546 Litres per day at latitude 51.8018, longitude -119.3231 within the Kamloops / North Branch district precinct in the water license watershed "UNTH-Avola".

Geology

The geology of the area is dominated by metamorphic fractured bedrock of the Shuswap Assemblage of Proterozoic to Paleozoic age. The original description "*undivided quartzofeldspathic gneiss, biotite-quartz schist (commonly with sillimanite, kyanite, garnet or staurolite), amphibolite, quartzite, marble, calc-silicate rock and skarn; abundant and locally dominant pegmatite, muscovite granite.*" The specific unit associated with the water license area is Malton Complex.

There are no mapped aquifers in the area, although the fractured bedrock hosts significant amounts of groundwater resources that is exploited throughout the region. In the vicinity of the license parcel are many springs that manifest on topographic benches that source positive head boundary (source) the creeks in the area including, but not limited to, Roddy Creek.

Climate Data

The current operating weather station in the area is at BLUE RIVER operated by ECCC - MSC, Latitude:52°07'44.400" N Longitude:119°17'23.700" W Elevation:682.80 m Climate ID:1160H99 WMO ID:71883. The climatic averages are presented below. Although these climate normal are from 1981-2010, Pacific Climate Impacts Consortium have estimated that winters will be milder and wetter and summers will be hotter and drier and spring flooding will be increased.

Table 1. Historic Canadian Climate Normals, Blue River, BC 1981-2010





Table 2. Canadian Climate Normals Precipitation, Blue River, BC 1981 -2010
1981 to 2010 Canadian Climate Normals station data

| | <u>Precipitation</u> | | | | | | | | | | | | |
|---|----------------------|---------|---------|---------|---------|---------|---------|---------|---------|----------------|---------|---------|--------|
| | Jan | Feb | Mar | Apr | May | Jun | Jul | Aug | Sep | Oct | Nov | Dec | Year |
| Rainfall (mm) | 21.3 | 17.6 | 35.8 | 52.7 | 75.6 | 98.8 | 107.3 | 82.4 | 71.3 | 94.0 | 49.5 | 13.5 | 719.7 |
| Snowfall (cm) | 113.5 | 49.5 | 38.3 | 7.0 | 0.4 | 0.0 | 0.0 | 0.0 | 0.0 | 10.0 | 82.4 | 103.4 | 404.4 |
| Precipitation (mm) | 105.4 | 53.8 | 64.7 | 58.7 | 75.8 | 98.8 | 107.3 | 82.4 | 71.3 | 102.5 | 115.2 | 88.4 | 1024.4 |
| Average Snow Depth (cm) | 72 | 78 | 62 | 13 | 0 | 0 | 0 | 0 | 0 | 0 | 14 | 43 | 24 |
| Median Snow Depth (cm) | 71 | 77 | 64 | 9 | 0 | 0 | 0 | 0 | 0 | 0 | 13 | 44 | 23 |
| Snow Depth at Month-end (cm) | 81 | 76 | 40 | 1 | 0 | 0 | 0 | 0 | 0 | 2 | 26 | 53 | 23 |
| Extreme Daily Rainfall (mm) | 30.6 | 17.8 | 22.0 | 31.6 | 29.2 | 44.4 | 44.9 | 35.1 | 40.4 | 47.4 | 38.8 | 35.8 | |
| Date (yyyy/dd) | 1992/31 | 1971/14 | 1993/06 | 2003/25 | 2002/20 | 1999/09 | 2006/09 | 1975/21 | 1978/02 | 2003/16 | 1983/15 | 1980/14 | |
| Extreme Daily Snowfall (cm) | 56.1 | 29.7 | 33.2 | 10.8 | 3.0 | 0.0 | 0.0 | 0.0 | 3.8 | 34.8 | 33.3 | 51.8 | |
| Date (yyyy/dd) | 1972/21 | 1975/10 | 1993/14 | 2003/03 | 1999/07 | 1970/01 | 1970/01 | 1970/01 | 1972/23 | 1975/29 | 1972/30 | 2000/16 | |
| Extreme Daily Precipitation (mm) | 41.8 | 22.9 | 26.2 | 32.0 | 29.2 | 44.4 | 44.9 | 35.1 | 40.4 | 47.4 | 42.4 | 45.6 | |
| Date (yyyy/dd) | 1986/18 | 1972/27 | 1993/14 | 2003/25 | 2002/20 | 1999/09 | 2006/09 | 1975/21 | 1978/02 | 2003/16 | 1998/12 | 1980/14 | |
| Extreme Snow Depth (cm) | 175 | 155 | 157 | 107 | 15 | 0 | 0 | 0 | 3 | 21 | 69 | 115 | |
| Date (yyyy/dd) | 1972/22 | 1974/04 | 1972/05 | 1975/03 | 1982/01 | 1970/01 | 1970/01 | 1970/01 | 1972/28 | 2004/23 | 1973/28 | 1984/21 | |

Short Duration Rainfall Intensity–Duration–Frequency Data

2021/03/26

Données sur l'intensité, la durée et la fréquence des chutes de pluie de courte durée



License Watershed Hydrology

The license is sourced from Roddy Creek within the North Thompson River watershed.

Table 3. Creek Watershed Source, Roddy Creek and Avola Creek, BC

| Creek Watershed | Sub-Catchment Area (Ha) | Gradient length (m) | Headwater Elevation (m asl) | Crossing Elevation (m asl) | Slope (m/m) |
|-----------------|-------------------------|---------------------|-----------------------------|----------------------------|-------------|
| Roddy Creek | 424.5 | 3405 | 1767 | 600 | 0.343 |
| Avola Creek | 305.5 | 3754 | 1876 | 637 | 0.330 |

Time of Concentration Estimation

Time of concentration (t_{ch}) for a watershed is a widely used time parameter to estimate peak discharges in hydrologic designs. The time of concentration of a watershed is the time required for runoff to travel from the hydraulically most distant point to the outlet of a watershed.

Time of concentration was determined for each catchment and combined to produce a fundamental watershed parameter that determines the peak discharge for the crossing. The Kirpich method was appropriate to determine time of concentration.

Where;

$$t_{ch} = KL^{0.770} S^{-0.385}$$

- t_{ch} time of concentration
- K unit conversion coefficient (0,195 SI units)
- L Travel Length (m)
- S slope (unitless)

Table 1. Rational Method Stream Hydraulics for the Kirpich Method

| Creek Watershed | Slope (m/m) | Travel length (m) | Time of Concentration (min) |
|-----------------|-------------|-------------------|-----------------------------|
| Roddy Creek | 0.343 | 21124 | 63 |
| Avola Creek | 0.330 | 12017 | 41 |

Rational Method Watershed Forecasting

The estimated discharge of overland flow draining from each sub-catchment contributing to the water licenses crossing was estimated using the rational method using the equation and then summed:

$$Q = 0.278 (CiA)$$

Where;

- Q the volume of overland flow draining off the sub-catchment in (m^3/s)
- C runoff coefficient (typically in forest environments this ranges from 0.05 - 0.25)
- i rainfall intensity for each return period or flood year (in mm/hr)
- A area of the sub-catchment (km^2)
- 0.278 standard unit conversion factor

The runoff coefficient for forested environments is typically 0.05 - 0.25. From vegetation surveys and other basin analysis; a runoff coefficient of 0.2 was selected for each catchment. Rainfall intensity was derived from the IDF values from Blue River CDA climate station. Peak discharge at selected

return-periods of 5-year, 10-year, 25-year, 50-year, and 100-year were determined for the sub-catchment area and it is conservatively assumed that all of the overland flow entering the streams during flooding conditions exists the sub-catchment through the crossing.

It is assumed that groundwater infiltration and evapotranspiration net change is minimal within the watershed and therefore not factored into flood hydrology analysis. Snowpack influence has also not been factored into flood hydrology analysis and therefore rain-on-snow events may produce flood volumes that are higher than those estimated by this method. For return periods a 10% conservative safety factor was applied to the discharge rates to address landscape variability and climate change.

Table 2. Rational Method Peak Stream Discharge

| Crossing ID | Return-Period | Rainfall Intensity | Peak Discharge | Adj. Peak Discharge |
|--------------------------------|---------------|--------------------|---------------------|---------------------|
| | (year) | (mm/hr) | (m ³ /s) | (m ³ /s) |
| Roddy Creek Watershed (62 min) | 100 | 20 | 4.4 | 5.1 |
| | 50 | 19 | 4.2 | 4.8 |
| | 25 | 18 | 4.0 | 4.6 |
| | 10 | 15 | 3.3 | 3.8 |
| | 5 | 12 | 2.6 | 3.0 |
| | 2 | 10 | 2.2 | 2.5 |
| Avola Creek Watershed (41 min) | 100 | 30 | 6.1 | 7.0 |
| | 50 | 28 | 6.2 | 7.1 |
| | 25 | 25 | 5.5 | 6.3 |
| | 10 | 20 | 4.4 | 5.1 |
| | 5 | 18 | 4.0 | 4.6 |
| | 2 | 12 | 2.6 | 3.0 |




Figure 1. 3D View of Roddy Creek Watershed

Forestry Operations Impacts to Water License

Through personal communications with the landowners, it is known that Avola area watersheds have a legacy of preservation and protection by community efforts and through sensible forestry management. Older second growth forests in sensitive watersheds were not traditionally included in forestry operations. The mature forests of the Avola and Roddy Creeks are likely the main contributing factor to sustainable licensed water resources on those creeks.

However, over the past years, sensitive watershed areas have been considered for intensive logging. Due to the significant topographic slope of the Avola Creek and Roddy Creek watersheds and the unique fractured/weathered bedrock that underlay the forest floor; intensive forestry operations in these watersheds like significant road cutting in the vicinity of the riparian areas and Streamside Protection and Enhancement Area (SPEA) is likely to cause significant and ongoing sediment transport into the receiving creeks. Sediment transport from erosion of forest floors and weathered bedrock can carry other bacteriological and chemical contaminants including but not limited to coliforms, heavy metals, and compounds that impacts pH and salinity of source water.

The recent road building extending from Avola Mountain Forestry Road and into the Roddy Creek is a significant industrial operation in a serene watershed. The approach angle of the road to the main creek crossing has outcropped many vertical metres of fractured bedrock by tens of meters in length. This has exposed water-saturated fractures that were actively springing into the road ditch. The downslope of the road is very steep and the vegetation has been removed down the slope to the creek. There were no natural or unnatural erosion mitigation measures to discourage sediment movement from the road and associated construction to the creek. It is likely that the groundwater discharge from the exposed rock-cut will not subside and that it will provide persistent

groundwater flow into the road ditch and eventually into the creek. Although the quantity of the groundwater discharge may be less significant compared to the surface water discharge, the concentration of solute that is carried by weathered bedrock can have significant impact to the water quality of the creek.

Water Quality Monitoring to Assess Impacts

On November 4, 2021 after noticing a visual spike in turbidity in their water system, the landowners collected water samples under the direct supervision of an Environmental Scientist competent and experienced in water quality monitoring and sample collection. Samples were submitted to ALS Laboratory in Kamloops, BC. Samples were analysed for routine chemistry, total metals, and coliform matter. On November 22, 2021 BCTS collected several water samples located upstream of their logging activities which were analysed for total metals and coliform matter. A review of the results show significant increase of select metals, coliform matter, and turbidity in the landowners water system when compared to results from upstream sample results. In particular analytical results from the landowner's samples exceeded Canadian Drinking Water Quality Guidelines for Maximum Acceptable Concentrations for coliform, aluminum, lead, manganese, and uranium.

Conclusions

Impacts to those licenses with a date of precedent of over half a century must be considered and are likely irreplaceable. The forestry operations in the headwaters of Roddy Creek have caused significant impact to the drinking water license F043942 with a date of precedent of August 17, 1959. It was identified by William Shulba, P.Geo in October 2021, that drinking water was directly disrupted by forestry practices in the Roddy Creek watershed specifically road building in the area. Further investigation included water samples collected from within the landowners potable water supply, results have which show several exceedances of Canadian Drinking Water Guidelines for Aesthetic Objective/Operational Guideline as well as exceedances of select metals and coliform matter for Maximum Acceptable Concentrations. Although some attention was given to this from the operators and BCTS, there was little compensation or alteration to the forestry practice to mitigate these issues or improve the landowners water system to meet code.

Recommendations

It is recommended that:

- The forestry operations in the Roddy Creek watershed be suspended and investigated by Ministry of Forests staff to ensure that the road building will not cause continued impacts to Roddy Creek, including but not limited to impacts to drinking water licenses and salmon habitat.
- Mitigation measures be established immediately to stop erosion and road cut groundwater from directly entering Roddy Creek and that those mitigation measures be implemented under the direct supervision of a Qualified Environmental Professional (QEP).
- Intensive forestry operations not continue in the Avola and Roddy Creek Watersheds for the protection of the drinking water licenses that source from those waterbodies.

- Water quality monitoring should be continued at the expense of the contractor, and under direct supervision of an engineer or geoscientist with competency in water quality monitoring.

Closure

This technical letter was written by William Shulba, P. Geo without compensation nor contract and provided a general watershed analysis and stream crossing hydrology for the purposes of recommendation for the protection of water license F043942 with a date of precedent of August 17, 1959 . This analysis and report was a desktop study that utilized basic survey elevation provided by LiDARBC, open-source data from the Regional District of Thompson-Nicola and the Province and laboratory test results collected by landowners from within their water system, and BCTS from up stream of logging and road building operations.

This technical letter pertains to a specific area, a specific site, a specific development, and a specific scope of work. It is not applicable to any other sites, nor should it be relied upon for types of development other than those to which it refers. Any variation of the site or development of the water license resource would necessitate a supplementary investigation and assessment.

This technical letter and the assessments and recommendations contained in it are intended for the sole use of educating the landowner of the parcel that contains water license F043942 with a date of precedent of August 17, 1959. The undersigned does not accept any responsibility for the accuracy of any of the data, the analysis or the recommendations contained or referenced in the report when the report is used or relied upon by any party other than educational purposes of the landowner unless otherwise authorized in writing by the undersigned.

This technical letter is based solely on the conditions which existed within the study area or on site at the time of investigation. The landowner and any other parties reviewing this letter with the express written consent of the undersigned, acknowledge that conditions affecting the environmental assessment of the site can vary with time and that the conclusions and recommendations set out in this report are time and subject sensitive.

Any party using this technical letter with the express written consent of the undersigned, acknowledge that the conclusions and recommendations set out in this technical letter are based on limited observations on the area and subject site and that conditions may vary across the site which, in turn, could affect the conclusions and recommendations made. The reviewer of this letter acknowledges that the undersigned is neither qualified to, nor is it making, any recommendations with respect to the maintenance, mitigation, purchase, sale, investment or development of the water license and property, the decisions on which are the sole responsibility of landowner.

During the performance of the work and the preparation of this letter, the undersigned may have relied on information provided by persons other than the landowner, including information from the Province and BCTS. While the undersigned endeavours to verify the accuracy of such information the undersigned accepts no responsibility for the accuracy or the reliability of such information which may affect the report.

Services performed by the undersigned for this report have been conducted in a manner consistent with the level of skill ordinarily exercised by members of

the Engineering and Geoscience profession currently practicing under similar conditions in the jurisdiction in which the services are provided. Engineering and geoscience judgement has been applied in developing the conclusions and/or recommendations provided in this report. No warranty or guarantee, express or implied, is made concerning the test results, comments, recommendations, or any other portion of this report.

The undersigned professional, William Shulba, P.Geoscientist is a professional geoscientist in good standing with the Engineers and Geoscientists of BC and has strived to utilize the most up to date guidance documentation and software packages for the analysis of this project and that there was no monetary exchange nor contract for this letter. This letter was hand delivered to the landowner for their educational purposes

Thank you for your consideration of these limitation and hope that they are received in good faith. If you have any questions please contact William Shulba, P.Geoscientist to have your questions or concerns addressed appropriately.

Thank you for your time and consideration,
William Shulba, P.Geoscientist

Appendix A. Photo Log



Photo 1. Erosion on Logging Road Above Landowners Water Supply November, 2021



Photo 2. Steep Road Construction and Erosion November, 2021



Photo 3. Road Construction Eroding into Roddy Creek November, 2021



Photo 4. Sediment Control Structures Requiring Maintenance with Extremely Turbid Water, November, 2021



Photo 5. Sediment Build Up in Landowner's Water System Intake



Photo 6. Sediment Build Up on the Water Intake of the Landowner's Water System



Photo 7. Turbid Water in Spring Near Landowners Water System Intake



Photo 8. Turbid Water in Landowners Water System Intake, November 2021



Photo 9. Highly Turbid Water in Landowners Water System with Plume of Sediment Visible, September 2021



Photo 10. Extremely Turbid Water in Landowners Water System, August 2021

Appendix B. Tabulated Water Quality Analytical Results

Appendix B Water Quality Analytical Results, 4317 Messiter Stn Rd Avola, BC

| Sample Information | | | | | | | | | |
|--|---------------|-----------------------|-----------------------|--------------------|--------------------|------------|------------|---------------|---------------------------------|
| Sampling ID | Sampling Date | Dissolved Nitrite (N) | Dissolved Nitrate (N) | Turbidity | Colour, true | Chloride | Fluoride | Sulfate (SO4) | Coliforms, Thermotolerant (Fec) |
| | | (dd-mmm-yyyy) | mg/L | mg/L | NTU | CU | mg/L | mg/L | mg/L |
| Groundwater Samples | | | | | | | | | |
| Seepage | 22-Nov-2021 | NA | NA | <i>26.3</i> | <i>41.9</i> | NA | NA | NA | <1 |
| Bridge Upstream | 22-Nov-2021 | NA | NA | <i>0.54</i> | <5.0 | NA | NA | NA | <1 |
| Bridge Downstream | 22-Nov-2021 | NA | NA | <i>1.69</i> | 5 | NA | NA | NA | <1 |
| Hydro Upstream | 22-Nov-2021 | NA | NA | <i>0.6</i> | <5.0 | NA | NA | NA | <1 |
| 2800 CMP Upstream | 22-Nov-2021 | NA | NA | <i>0.25</i> | <5.0 | NA | NA | NA | <1 |
| 2800 CMP Downstream | 22-Nov-2021 | NA | NA | <i>0.41</i> | <5.0 | NA | NA | NA | <1 |
| POD | 22-Nov-2021 | NA | NA | <i>0.6</i> | <5.0 | NA | NA | NA | <i>1</i> |
| Pond (Collected by Owner) | 4-Nov-2021 | 0.0011 | 0.0492 | <i>192</i> | 9.9 | <0.50 | 0.092 | 4.71 | NA |
| Canadian Drinking Water Quality, Aesthetic Objective/Operational Guideline | | NG | NG | 0.1 | 15 | 250 | NG | NG | |
| Canadian Drinking Water Quality, Maximum Acceptable Concentrations | | 1 | 10 | NG | NG | NG | 1.5 | NG | |
| Notes: | | | | | | | | | |
| Analytical results greater than the referenced Canadian Drinking Water Maximum Acceptable Concentration shown in red highlighted font | | | | | | | | | |
| Analytical results greater than the referenced Canadian Drinking Water Maximum Acceptable Concentration shown in italicized font | | | | | | | | | |
| NA - not analyzed | | | | | | | | | |
| NG - no guideline | | | | | | | | | |
| mg/L - milligrams per litre | | | | | | | | | |
| µg/L - micrograms per litre | | | | | | | | | |

Appendix B Water Quality Analytical Results, 4317 Messiter Stn Rd Avola, BC

Table 1

Water Quality Sample Analytical Results - Routine Parameters
2021 Water Quality Test Results 314 Messiter Station Rd, Avola BC

| Laboratory Analytical Results | | | | | | | | | | | | | | | | | | |
|-------------------------------|--------------------|------------------|------------------------|--------------|-----------------|-----------------------------|---------------------|---------------------|--------------------|-------------------|----------------------|--------------------|-----------------|--------------------|--------------------|--------------|---------------------|-------------------|
| Total Coliforms | Coliforms, E. Coli | Hardness (CaCO3) | Total Dissolved Solids | Conductivity | pH | Alkalinity (Total as CaCO3) | Total Aluminum (Al) | Total Antimony (Sb) | Total Arsenic (As) | Total Barium (Ba) | Total Beryllium (Be) | Total Bismuth (Bi) | Total Boron (B) | Total Cadmium (Cd) | Total Calcium (Ca) | Total Cesium | Total Chromium (Cr) | Total Cobalt (Co) |
| MPN/100ml | | mg/L | mg/L | uS/cm | pH | mg/L | mg/L | mg/L | mg/L | mg/L | mg/L | mg/L | mg/L | mg/L | mg/L | mg/L | mg/L | mg/L |
| NA | NA | 9.43 | NA | NA | NA | NA | 2.75 | <0.00010 | 0.00024 | 0.0297 | 0.000135 | 0.000065 | <0.010 | 0.0000131 | 2.06 | 0.000359 | 0.0022 | 0.00078 |
| NA | NA | 45.3 | NA | NA | NA | NA | 0.0516 | <0.00010 | <0.00010 | 0.00496 | <0.00010 | <0.000050 | <0.010 | <0.0000050 | 14.7 | 0.000015 | <0.00050 | <0.00010 |
| NA | NA | 44.1 | NA | NA | NA | NA | 0.14 | <0.00010 | <0.00010 | 0.00604 | <0.00010 | <0.000050 | <0.010 | <0.0000050 | 14.2 | 0.00003 | <0.00050 | <0.00010 |
| NA | NA | 45.1 | NA | NA | NA | NA | 0.0519 | <0.00010 | <0.00010 | 0.00485 | <0.00010 | <0.000050 | <0.010 | <0.0000050 | 14.7 | 0.000018 | <0.00050 | <0.00010 |
| NA | NA | 48 | NA | NA | NA | NA | 0.0292 | <0.00010 | <0.00010 | 0.00392 | <0.00010 | <0.000050 | <0.010 | <0.0000050 | 15.9 | 0.000016 | <0.00050 | <0.00010 |
| NA | NA | 46.8 | NA | NA | NA | NA | 0.0439 | <0.00010 | <0.00010 | 0.00399 | <0.00010 | <0.000050 | <0.010 | <0.0000050 | 15.6 | 0.000021 | <0.00050 | <0.00010 |
| NA | NA | 46 | NA | NA | NA | NA | 0.0631 | <0.00010 | <0.00010 | 0.00473 | <0.00010 | <0.000050 | <0.010 | <0.0000050 | 15.1 | 0.000018 | <0.00050 | <0.00010 |
| 727 | 5 | 78.8 | 65 | 112 | 7.69 | 63.5 | 8.85 | <0.0050 | 0.00112 | 0.0798 | NA | NA | <0.100 | 0.000244 | 24.3 | NA | 0.0108 | NA |
| NG | NG | NG | 500 | NG | 7.0-10.5 | NG | 0.1 | NG | NG | NG | NG | NG | NG | NG | NG | NG | NG | NG |
| 1 | 1 | NG | NG | NG | NG | NG | 2.9 | 0.006 | 0.01 | 2 | NG | NG | 5 | 0.007 | NG | NG | 0.05 | NG |

Appendix B Water Quality Analytical Results, 4317 Messiter Stn Rd Avola, BC

| Total Copper (Cu) | Total Iron (Fe) | Total Lead (Pb) | Total Lithium (Li) | Total Magnesium (Mg) | Total Manganese (Mn) | Total Molybdenum (Mo) | Total Mercury (Hg) | Total Nickel (Ni) | Total Phosphorous (P) | Total Potassium (K) | Rubidium (Rb) | Total Selenium (Se) | Total Silicon (Si) | Total Silver (Ag) | Total Strontium (Sr) | Total Sodium (Na) | Total Uranium (U) | Total Zinc |
|-------------------|-----------------|-----------------|--------------------|----------------------|----------------------|-----------------------|--------------------|-------------------|-----------------------|---------------------|---------------|---------------------|--------------------|-------------------|----------------------|-------------------|-------------------|------------|
| mg/L | mg/L | mg/L | mg/L | mg/L | mg/L | mg/L | mg/L | mg/L | mg/L | mg/L | mg/L | mg/L | mg/L | mg/L | mg/L | mg/L | mg/L | mg/L |
| 0.00314 | 2.07 | 0.00111 | 0.0032 | 1.04 | 0.0716 | 0.000393 | <0.0000050 | 0.0018 | 0.073 | 1.46 | 0.00709 | 0.00019 | 10.6 | 0.000022 | 0.0198 | 1.85 | 0.000622 | 0.0067 |
| <0.00050 | 0.036 | <0.000050 | 0.0023 | 2.08 | 0.00178 | 0.00192 | <0.0000050 | <0.00050 | <0.050 | 0.657 | 0.00089 | <0.000050 | 4.91 | <0.000010 | 0.138 | 1.85 | 0.00737 | <0.0030 |
| 0.00103 | 0.118 | 0.000096 | 0.0023 | 2.1 | 0.00362 | 0.00181 | <0.0000050 | 0.00053 | <0.050 | 0.728 | 0.00121 | <0.000050 | 5.28 | <0.000010 | 0.132 | 1.94 | 0.00753 | <0.0030 |
| <0.00050 | 0.036 | <0.000050 | 0.0023 | 2.04 | 0.00167 | 0.0019 | <0.0000050 | <0.00050 | <0.050 | 0.656 | 0.00092 | <0.000050 | 5.04 | <0.000010 | 0.144 | 1.84 | 0.00768 | <0.0030 |
| <0.00050 | 0.022 | <0.000050 | 0.0024 | 2.01 | 0.00091 | 0.00153 | <0.0000050 | <0.00050 | <0.050 | 0.693 | 0.0008 | <0.000050 | 5.03 | <0.000010 | 0.121 | 1.86 | 0.00476 | <0.0030 |
| <0.00050 | 0.038 | <0.000050 | 0.0024 | 1.9 | 0.00156 | 0.00143 | <0.0000050 | <0.00050 | <0.050 | 0.68 | 0.00084 | 0.000074 | 4.83 | <0.000010 | 0.115 | 1.78 | 0.00479 | <0.0030 |
| <0.00050 | 0.046 | <0.000050 | 0.0022 | 2.01 | 0.00152 | 0.0016 | <0.0000050 | <0.00050 | <0.050 | 0.71 | 0.00094 | <0.000050 | 5.05 | <0.000010 | 0.121 | 1.92 | 0.00526 | <0.0030 |
| 0.0264 | 9.91 | 0.0101 | NA | 4.4 | 0.33 | NA | 0.0000504 | NA | NA | 2.12 | NA | 0.00162 | NA | NA | NA | 2.33 | 0.106 | <0.0500 |
| 1 | 0.3 | NG | NG | NG | 0.02 | NG | NG | NG | NG | NG | NG | NG | NG | NG | | 200 | NG | 5 |
| 2 | NG | 0.005 | NG | NG | 0.12 | NG | 0.001 | NG | NG | NG | NG | 0.05 | NG | NG | | NG | 0.02 | NG |

Appendix C. ALS Laboratory Reports

CERTIFICATE OF ANALYSIS (GUIDELINE EVALUATION)

| | |
|--|--|
| Work Order : KS2103651 Client : Cash Clients Canada Contact : Kris Olson Address : BC Canada Telephone : 778-208-4781 Project : 4137 Messiter Stn Rd, Avola BC PO : ---- C-O-C number : 20-933883 Sampler : ---- Site : ---- Quote number : Kamloops Cash Client Pricing No. of samples received : 1 No. of samples analysed : 1 | Page : 1 of 6 Laboratory : Kamloops - Environmental Account Manager : Caitlin Fountain Address : 1445 McGill Road, Unit 2B Kamloops, British Columbia Canada V2C 6K7 Telephone : 250 372 3588 Date Samples Received : 04-Nov-2021 13:15 Date Analysis Commenced : 04-Nov-2021 Issue Date : 09-Nov-2021 13:28 |
|--|--|

This report supersedes any previous report(s) with this reference. Results apply to the sample(s) as submitted. This document shall not be reproduced, except in full.

This Certificate of Analysis contains the following information:

- General Comments
- Analytical Results
- Guideline Comparison

Additional information pertinent to this report will be found in the following separate attachments: Quality Control Report, QC Interpretive report to assist with Quality Review and Sample Receipt Notification (SRN).

Signatories

This document has been electronically signed by the authorized signatories below. Electronic signing is conducted in accordance with US FDA 21 CFR Part 11.

| <i>Signatories</i> | <i>Position</i> | <i>Laboratory Department</i> |
|--------------------|---------------------------------|--|
| Amanda Lampreau | Laboratory _ Supervisor | Microbiology, Kamloops, British Columbia |
| Angela Ren | Team Leader - Metals | Metals, Burnaby, British Columbia |
| Caleb Deroche | Lab Analyst | Metals, Burnaby, British Columbia |
| Miles Gropen | Department Manager - Inorganics | Inorganics, Burnaby, British Columbia |

General Comments

The analytical methods used by ALS are developed using internationally recognized reference methods (where available), such as those published by US EPA, APHA Standard Methods, ASTM, ISO, Environment Canada, BC MOE, and Ontario MOE. Refer to the ALS Quality Control Interpretive report (QCI) for applicable references and methodology summaries. Reference methods may incorporate modifications to improve performance.

Where a reported less than (<) result is higher than the LOR, this may be due to primary sample extract/digestate dilution and/or insufficient sample for analysis.

Where the LOR of a reported result differs from standard LOR, this may be due to high moisture content, insufficient sample (reduced weight employed) or matrix interference.

Additional information pertinent to this report will be found in the following separate attachments: Quality Control Report, QA/QC Compliance Assessment to assist with Quality Review and Sample Receipt Notification.

When sampling time information is not provided by the client, sampling dates are shown without a time component. In these instances, the time component has been assumed by the laboratory for processing purposes.

Application of guidelines is provided "as is" without warranty of any kind, either expressed or implied, including, but not limited to fitness for a particular purpose, or non-infringement. ALS assumes no responsibility for errors or omissions in the information. Guidelines are not adjusted for the hardness, pH or temperature of the sample (the most conservative values are used). Measurement uncertainty is not applied to test results prior to comparison with specified criteria values.

Key : LOR: Limit of Reporting (detection limit).

| <i>Unit</i> | <i>Description</i> |
|-------------|---------------------------------|
| µS/cm | Microsiemens per centimetre |
| CU | colour units (1 CU = 1 mg/L Pt) |
| mg/L | milligrams per litre |
| MPN/100mL | most probable number per 100 mL |
| NTU | nephelometric turbidity units |
| pH units | pH units |

>: greater than.

<: less than.

Red shading is applied where the result is greater than the Guideline Upper Limit or the result is lower than the Guideline Lower Limit.

For drinking water samples, Red shading is applied where the result for E.coli, fecal or total coliforms is greater than or equal to the Guideline Upper Limit.



Analytical Results

| | | | | Client sample ID | 4137 Messiter Stn Rd Avola BC | | | | | |
|---------------------------------------|------------|----------|-----------|--------------------|----------------------------------|--------------|--|--|--|--|
| Sub-Matrix: Water (Matrix: Water) | | | | Sampling date/time | 03-Nov-2021 20:25 | | | | | |
| Analyte | Method | LOR | Unit | KS2103651-001 | CDWG AO/OG | CDWG MAC | | | | |
| Physical Tests | | | | | | | | | | |
| alkalinity, total (as CaCO3) | E290 | 1.0 | mg/L | 63.5 | -- | -- | | | | |
| colour, true | E329 | 5.0 | CU | 9.9 | 15 | -- | | | | |
| conductivity | E100 | 2.0 | µS/cm | 112 | -- | -- | | | | |
| pH | E108 | 0.10 | pH units | 7.69 | 7 - 10.5 | -- | | | | |
| solids, total dissolved [TDS] | E162 | 10 | mg/L | 65 | 500 | -- | | | | |
| turbidity | E121 | 0.10 | NTU | 192 | 0.1 | -- | | | | |
| hardness (as CaCO3), from total Ca/Mg | EC100A | 0.60 | mg/L | 78.8 | -- | -- | | | | |
| Anions and Nutrients | | | | | | | | | | |
| chloride | E235.Cl | 0.50 | mg/L | <0.50 | 250 | -- | | | | |
| fluoride | E235.F | 0.020 | mg/L | 0.092 | -- | 1.5 | | | | |
| nitrate (as N) | E235.NO3-L | 0.0050 | mg/L | 0.0492 | -- | 10 | | | | |
| nitrite (as N) | E235.NO2-L | 0.0010 | mg/L | 0.0011 | -- | 1 | | | | |
| sulfate (as SO4) | E235.SO4 | 0.30 | mg/L | 4.71 | -- | -- | | | | |
| Bacteriological Tests | | | | | | | | | | |
| coliforms, total | E010 | 1 | MPN/100mL | 727 | -- | 1 | | | | |
| coliforms, Escherichia coli [E. coli] | E010 | 1 | MPN/100mL | 5 | -- | 1 | | | | |
| Total Metals | | | | | | | | | | |
| aluminum, total | E420 | 0.0100 | mg/L | 8.85 | 0.1 | 2.9 | | | | |
| antimony, total | E420 | 0.00050 | mg/L | <0.00050 | -- | 0.006 | | | | |
| arsenic, total | E420 | 0.00010 | mg/L | 0.00112 | -- | 0.01 | | | | |
| barium, total | E420 | 0.0200 | mg/L | 0.0798 | -- | 2 | | | | |
| boron, total | E420 | 0.100 | mg/L | <0.100 | -- | 5 | | | | |
| cadmium, total | E420 | 0.000200 | mg/L | 0.000244 | -- | 0.007 | | | | |
| calcium, total | E420 | 0.100 | mg/L | 24.3 | -- | -- | | | | |
| chromium, total | E420 | 0.00200 | mg/L | 0.0108 | -- | 0.05 | | | | |
| copper, total | E420 | 0.00100 | mg/L | 0.0264 | 1 | 2 | | | | |
| iron, total | E420 | 0.030 | mg/L | 9.91 | 0.3 | -- | | | | |
| lead, total | E420 | 0.000500 | mg/L | 0.0101 | -- | 0.005 | | | | |
| magnesium, total | E420 | 0.100 | mg/L | 4.40 | -- | -- | | | | |



| Analyte | Method | LOR | Unit | KS2103651-001 (Continued) | CDWG AO/OG | CDWG MAC | | | | |
|---------------------------------|--------|-----------|------|------------------------------|---------------|-------------|--|--|--|--|
| Total Metals - Continued | | | | | | | | | | |
| manganese, total | E420 | 0.00200 | mg/L | 0.330 | 0.02 | 0.12 | | | | |
| mercury, total | E508 | 0.0000050 | mg/L | 0.0000504 | -- | 0.001 | | | | |
| potassium, total | E420 | 0.100 | mg/L | 2.12 | -- | -- | | | | |
| selenium, total | E420 | 0.00100 | mg/L | 0.00162 | -- | 0.05 | | | | |
| sodium, total | E420 | 2.00 | mg/L | 2.33 | 200 | -- | | | | |
| uranium, total | E420 | 0.000100 | mg/L | 0.106 | -- | 0.02 | | | | |
| zinc, total | E420 | 0.0500 | mg/L | <0.0500 | 5 | -- | | | | |

Please refer to the General Comments section for an explanation of any qualifiers detected.



Summary of Guideline Breaches by Sample

| SampleID/Client ID | Matrix | Analyte | Analyte Summary | Guideline | Category | Result | Limit |
|-------------------------------|--------|---------------------------------------|---|-----------|----------|---------------|-------------|
| 4137 Messiter Stn Rd Avola BC | Water | turbidity | For systems that use groundwater, turbidity should generally be below 1.0 NTU. Filtration systems should be designed and operated to reduce turbidity levels as low as reasonably achievable and strive to achieve a treated water turbidity target from individual filters of less than 0.1 NTU. | CDWG | AO/OG | 192 NTU | 0.1 NTU |
| | Water | aluminum, total | There is no consistent, convincing evidence that aluminum in drinking water causes adverse health effects in humans. The operational guideline applies to treatment plants using aluminum-based coagulants; it does not apply to naturally occurring aluminum found in groundwater. For treatment plants using aluminum-based coagulants, monthly samples should be taken of the water leaving the plant; the OGs are based on a running annual average of monthly samples. | CDWG | AO/OG | 8.85 mg/L | 0.1 mg/L |
| | Water | iron, total | Based on taste and staining of laundry and plumbing fixtures; no evidence exists of dietary iron toxicity in the general population. | CDWG | AO/OG | 9.91 mg/L | 0.3 mg/L |
| | Water | manganese, total | Based on taste and staining of laundry and plumbing fixtures. | CDWG | AO/OG | 0.330 mg/L | 0.02 mg/L |
| | Water | coliforms, Escherichia coli [E. coli] | The presence of E. coli indicates recent faecal contamination and the potential presence of microorganisms capable of causing gastrointestinal illnesses; pathogens in human and animal faeces pose the most immediate danger to public health. | CDWG | MAC | 5 MPN/100mL | 1 MPN/100mL |
| | Water | coliforms, total | Total coliforms are not used as indicators of potential health effects from pathogenic microorganisms; they are used as a tool to determine how well the drinking water treatment system is operating and to indicate water quality changes in the distribution system. Detection of total coliforms from consecutive samples from the same site or from more than 10% of the samples collected in a given sampling period should be investigated. | CDWG | MAC | 727 MPN/100mL | 1 MPN/100mL |
| | Water | aluminum, total | Aluminum is not an essential element. Studies in humans have found possible associations between aluminum ingestion and diseases of the nervous system. However, these studies have a number of design limitations and do not provide strong evidence that aluminum can cause these diseases. Studies in animals have consistently observed adverse effects on the nervous system following ingestion of high levels of aluminum, which supports effects seen in human studies. | CDWG | MAC | 8.85 mg/L | 2.9 mg/L |



General Comments

The analytical methods used by ALS are developed using internationally recognized reference methods (where available), such as those published by US EPA, APHA Standard Methods, ASTM, ISO, Environment Canada, BC MOE, and Ontario MOE. Refer to the ALS Quality Control Interpretive report (QCI) for applicable references and methodology summaries. Reference methods may incorporate modifications to improve performance.

Where a reported less than (<) result is higher than the LOR, this may be due to primary sample extract/digestate dilution and/or insufficient sample for analysis.

Where the LOR of a reported result differs from standard LOR, this may be due to high moisture content, insufficient sample (reduced weight employed) or matrix interference.

Additional information pertinent to this report will be found in the following separate attachments: Quality Control Report, QA/QC Compliance Assessment to assist with Quality Review and Sample Receipt Notification.

When sampling time information is not provided by the client, sampling dates are shown without a time component. In these instances, the time component has been assumed by the laboratory for processing purposes.

Application of guidelines is provided "as is" without warranty of any kind, either expressed or implied, including, but not limited to fitness for a particular purpose, or non-infringement. ALS assumes no responsibility for errors or omissions in the information. Guidelines are not adjusted for the hardness, pH or temperature of the sample (the most conservative values are used). Measurement uncertainty is not applied to test results prior to comparison with specified criteria values.

Key : LOR: Limit of Reporting (detection limit).

| <i>Unit</i> | <i>Description</i> |
|-------------|---------------------------------|
| CFU/100mL | colony forming units per 100 mL |
| CU | colour units (1 CU = 1 mg/L Pt) |
| mg/L | milligrams per litre |
| NTU | nephelometric turbidity units |

>: greater than.

<: less than.

Red shading is applied where the result is greater than the Guideline Upper Limit or the result is lower than the Guideline Lower Limit.

For drinking water samples, Red shading is applied where the result for E.coli, fecal or total coliforms is greater than or equal to the Guideline Upper Limit.



Analytical Results Evaluation

| | | | Client sample ID | | | | | | |
|---------------------------------------|------------|-----------|----------------------|----------------------|----------------------|----------------------|----------------------|----------------------|----------------------|
| Matrix: Water | | | Seepage | Bridge Upstream | Bridge Downstream | Hydro Upstream | 2800 CMP Upstream | 2800 CMP Downstream | POD |
| Sampling date/time | | | 22-Nov-2021 13:22 | 22-Nov-2021 13:34 | 22-Nov-2021 13:45 | 22-Nov-2021 13:27 | 22-Nov-2021 13:59 | 22-Nov-2021 14:01 | 22-Nov-2021 14:44 |
| Sub-Matrix | | | Water |
| Analyte | CAS Number | Unit | KS2103836-001 | KS2103836-002 | KS2103836-003 | KS2103836-004 | KS2103836-005 | KS2103836-006 | KS2103836-007 |
| Physical Tests | | | | | | | | | |
| colour, true | ---- | CU | 41.9 | <5.0 | 5.0 | <5.0 | <5.0 | <5.0 | <5.0 |
| hardness (as CaCO3), from total Ca/Mg | ---- | mg/L | 9.43 | 45.3 | 44.1 | 45.1 | 48.0 | 46.8 | 46.0 |
| turbidity | ---- | NTU | 26.3 | 0.54 | 1.69 | 0.60 | 0.25 | 0.41 | 0.60 |
| Bacteriological Tests | | | | | | | | | |
| coliforms, thermotolerant [fecal] | ---- | CFU/100mL | <1 | <1 | <1 | <1 | <1 | <1 | 1 |
| Total Metals | | | | | | | | | |
| aluminum, total | 7429-90-5 | mg/L | 2.75 | 0.0516 | 0.140 | 0.0519 | 0.0292 | 0.0439 | 0.0631 |
| antimony, total | 7440-36-0 | mg/L | <0.00010 | <0.00010 | <0.00010 | <0.00010 | <0.00010 | <0.00010 | <0.00010 |
| arsenic, total | 7440-38-2 | mg/L | 0.00024 | <0.00010 | <0.00010 | <0.00010 | <0.00010 | <0.00010 | <0.00010 |
| barium, total | 7440-39-3 | mg/L | 0.0297 | 0.00496 | 0.00604 | 0.00485 | 0.00392 | 0.00399 | 0.00473 |
| beryllium, total | 7440-41-7 | mg/L | 0.000135 | <0.000100 | <0.000100 | <0.000100 | <0.000100 | <0.000100 | <0.000100 |
| bismuth, total | 7440-69-9 | mg/L | 0.000065 | <0.000050 | <0.000050 | <0.000050 | <0.000050 | <0.000050 | <0.000050 |
| boron, total | 7440-42-8 | mg/L | <0.010 | <0.010 | <0.010 | <0.010 | <0.010 | <0.010 | <0.010 |
| cadmium, total | 7440-43-9 | mg/L | 0.0000131 | <0.0000050 | <0.0000050 | <0.0000050 | <0.0000050 | <0.0000050 | <0.0000050 |
| calcium, total | 7440-70-2 | mg/L | 2.06 | 14.7 | 14.2 | 14.7 | 15.9 | 15.6 | 15.1 |
| cesium, total | 7440-46-2 | mg/L | 0.000359 | 0.000015 | 0.000030 | 0.000018 | 0.000016 | 0.000021 | 0.000018 |
| chromium, total | 7440-47-3 | mg/L | 0.00220 | <0.00050 | <0.00050 | <0.00050 | <0.00050 | <0.00050 | <0.00050 |
| cobalt, total | 7440-48-4 | mg/L | 0.00078 | <0.00010 | <0.00010 | <0.00010 | <0.00010 | <0.00010 | <0.00010 |
| copper, total | 7440-50-8 | mg/L | 0.00314 | <0.00050 | 0.00103 | <0.00050 | <0.00050 | <0.00050 | <0.00050 |
| iron, total | 7439-89-6 | mg/L | 2.07 | 0.036 | 0.118 | 0.036 | 0.022 | 0.038 | 0.046 |
| lead, total | 7439-92-1 | mg/L | 0.00111 | <0.000050 | 0.000096 | <0.000050 | <0.000050 | <0.000050 | <0.000050 |
| lithium, total | 7439-93-2 | mg/L | 0.0032 | 0.0023 | 0.0023 | 0.0023 | 0.0024 | 0.0024 | 0.0022 |
| magnesium, total | 7439-95-4 | mg/L | 1.04 | 2.08 | 2.10 | 2.04 | 2.01 | 1.90 | 2.01 |
| manganese, total | 7439-96-5 | mg/L | 0.0716 | 0.00178 | 0.00362 | 0.00167 | 0.00091 | 0.00156 | 0.00152 |
| mercury, total | 7439-97-6 | mg/L | <0.0000050 | <0.0000050 | <0.0000050 | <0.0000050 | <0.0000050 | <0.0000050 | <0.0000050 |
| molybdenum, total | 7439-98-7 | mg/L | 0.000393 | 0.00192 | 0.00181 | 0.00190 | 0.00153 | 0.00143 | 0.00160 |
| nickel, total | 7440-02-0 | mg/L | 0.00180 | <0.00050 | 0.00053 | <0.00050 | <0.00050 | <0.00050 | <0.00050 |



Analytical Results Evaluation

| Matrix: Water | | | Client sample ID | Seepage | Bridge Upstream | Bridge Downstream | Hydro Upstream | 2800 CMP Upstream | 2800 CMP Downstream | POD |
|---------------------|------------|------|----------------------|----------------------|----------------------|----------------------|----------------------|----------------------|----------------------|--------|
| Sampling date/time | | | 22-Nov-2021 13:22 | 22-Nov-2021 13:34 | 22-Nov-2021 13:45 | 22-Nov-2021 13:27 | 22-Nov-2021 13:59 | 22-Nov-2021 14:01 | 22-Nov-2021 14:44 | |
| Sub-Matrix | | | Water | Water |
| Analyte | CAS Number | Unit | KS2103836-001 | KS2103836-002 | KS2103836-003 | KS2103836-004 | KS2103836-005 | KS2103836-006 | KS2103836-007 | |
| Total Metals | | | | | | | | | | |
| phosphorus, total | 7723-14-0 | mg/L | 0.073 | <0.050 | <0.050 | <0.050 | <0.050 | <0.050 | <0.050 | <0.050 |
| potassium, total | 7440-09-7 | mg/L | 1.46 | 0.657 | 0.728 | 0.656 | 0.693 | 0.680 | 0.710 | |
| rubidium, total | 7440-17-7 | mg/L | 0.00709 | 0.00089 | 0.00121 | 0.00092 | 0.00080 | 0.00084 | 0.00094 | |
| selenium, total | 7782-49-2 | mg/L | 0.000119 | <0.000050 | <0.000050 | <0.000050 | <0.000050 | 0.000074 | <0.000050 | |
| silicon, total | 7440-21-3 | mg/L | 10.6 | 4.91 | 5.28 | 5.04 | 5.03 | 4.83 | 5.05 | |
| silver, total | 7440-22-4 | mg/L | 0.000022 | <0.000010 | <0.000010 | <0.000010 | <0.000010 | <0.000010 | <0.000010 | |
| sodium, total | 17341-25-2 | mg/L | 1.85 | 1.85 | 1.94 | 1.84 | 1.86 | 1.78 | 1.92 | |
| strontium, total | 7440-24-6 | mg/L | 0.0198 | 0.138 | 0.132 | 0.144 | 0.121 | 0.115 | 0.121 | |
| sulfur, total | 7704-34-9 | mg/L | <0.50 | 1.79 | 1.88 | 1.58 | 2.08 | 1.98 | 1.89 | |
| tellurium, total | 13494-80-9 | mg/L | <0.00020 | <0.00020 | <0.00020 | <0.00020 | <0.00020 | <0.00020 | <0.00020 | |
| thallium, total | 7440-28-0 | mg/L | 0.000036 | <0.000010 | <0.000010 | <0.000010 | <0.000010 | <0.000010 | <0.000010 | |
| thorium, total | 7440-29-1 | mg/L | 0.00017 | <0.00010 | <0.00010 | <0.00010 | <0.00010 | <0.00010 | 0.00010 | |
| tin, total | 7440-31-5 | mg/L | <0.00010 | <0.00010 | <0.00010 | <0.00010 | <0.00010 | <0.00010 | <0.00010 | |
| titanium, total | 7440-32-6 | mg/L | 0.0678 | 0.00114 | 0.00358 | 0.00111 | 0.00059 | 0.00123 | 0.00149 | |
| tungsten, total | 7440-33-7 | mg/L | <0.00010 | <0.00010 | <0.00010 | <0.00010 | <0.00010 | <0.00010 | <0.00010 | |
| uranium, total | 7440-61-1 | mg/L | 0.000622 | 0.00737 | 0.00753 | 0.00768 | 0.00476 | 0.00479 | 0.00526 | |
| vanadium, total | 7440-62-2 | mg/L | 0.00360 | <0.00050 | <0.00050 | <0.00050 | <0.00050 | <0.00050 | <0.00050 | |
| zinc, total | 7440-66-6 | mg/L | 0.0067 | <0.0030 | <0.0030 | <0.0030 | <0.0030 | <0.0030 | <0.0030 | |
| zirconium, total | 7440-67-7 | mg/L | 0.00038 | <0.00020 | <0.00020 | <0.00020 | <0.00020 | <0.00020 | <0.00020 | |

Please refer to the General Comments section for an explanation of any qualifiers detected.



Summary of Guideline Breaches by Sample

| SampleID/Client ID | Matrix | Analyte | Analyte Summary | Guideline | Category | Result | Limit |
|---------------------|--------|-----------------|---|-----------|----------|------------|----------|
| 2800 CMP Downstream | Water | turbidity | For systems that use groundwater, turbidity should generally be below 1.0 NTU. Filtration systems should be designed and operated to reduce turbidity levels as low as reasonably achievable and strive to achieve a treated water turbidity target from individual filters of less than 0.1 NTU. | CDWG | AO/OG | 0.41 NTU | 0.1 NTU |
| | Water | turbidity | For systems that use groundwater, turbidity should generally be below 1.0 NTU. Filtration systems should be designed and operated to reduce turbidity levels as low as reasonably achievable and strive to achieve a treated water turbidity target from individual filters of less than 0.1 NTU. | CDWG | MAC | 0.41 NTU | 0.1 NTU |
| 2800 CMP Upstream | Water | turbidity | For systems that use groundwater, turbidity should generally be below 1.0 NTU. Filtration systems should be designed and operated to reduce turbidity levels as low as reasonably achievable and strive to achieve a treated water turbidity target from individual filters of less than 0.1 NTU. | CDWG | AO/OG | 0.25 NTU | 0.1 NTU |
| | Water | turbidity | For systems that use groundwater, turbidity should generally be below 1.0 NTU. Filtration systems should be designed and operated to reduce turbidity levels as low as reasonably achievable and strive to achieve a treated water turbidity target from individual filters of less than 0.1 NTU. | CDWG | MAC | 0.25 NTU | 0.1 NTU |
| Bridge Downstream | Water | turbidity | For systems that use groundwater, turbidity should generally be below 1.0 NTU. Filtration systems should be designed and operated to reduce turbidity levels as low as reasonably achievable and strive to achieve a treated water turbidity target from individual filters of less than 0.1 NTU. | CDWG | AO/OG | 1.69 NTU | 0.1 NTU |
| | Water | aluminum, total | There is no consistent, convincing evidence that aluminum in drinking water causes adverse health effects in humans. The operational guideline applies to treatment plants using aluminum-based coagulants; it does not apply to naturally occurring aluminum found in groundwater. For treatment plants using aluminum-based coagulants, monthly samples should be taken of the water leaving the plant; the OGs are based on a running annual average of monthly samples. | CDWG | AO/OG | 0.140 mg/L | 0.1 mg/L |
| | Water | turbidity | For systems that use groundwater, turbidity should generally be below 1.0 NTU. Filtration systems should be designed and operated to reduce turbidity levels as low as reasonably achievable and strive to achieve a treated water turbidity target from individual filters of less than 0.1 NTU. | CDWG | MAC | 1.69 NTU | 0.1 NTU |



| SampleID/Client ID | Matrix | Analyte | Analyte Summary | Guideline | Category | Result | Limit |
|--------------------|--------|-----------------------------------|---|-----------|----------|-------------|-------------|
| Bridge Upstream | Water | turbidity | For systems that use groundwater, turbidity should generally be below 1.0 NTU. Filtration systems should be designed and operated to reduce turbidity levels as low as reasonably achievable and strive to achieve a treated water turbidity target from individual filters of less than 0.1 NTU. | CDWG | AO/OG | 0.54 NTU | 0.1 NTU |
| | Water | turbidity | For systems that use groundwater, turbidity should generally be below 1.0 NTU. Filtration systems should be designed and operated to reduce turbidity levels as low as reasonably achievable and strive to achieve a treated water turbidity target from individual filters of less than 0.1 NTU. | CDWG | MAC | 0.54 NTU | 0.1 NTU |
| Hydro Upstream | Water | turbidity | For systems that use groundwater, turbidity should generally be below 1.0 NTU. Filtration systems should be designed and operated to reduce turbidity levels as low as reasonably achievable and strive to achieve a treated water turbidity target from individual filters of less than 0.1 NTU. | CDWG | AO/OG | 0.60 NTU | 0.1 NTU |
| | Water | turbidity | For systems that use groundwater, turbidity should generally be below 1.0 NTU. Filtration systems should be designed and operated to reduce turbidity levels as low as reasonably achievable and strive to achieve a treated water turbidity target from individual filters of less than 0.1 NTU. | CDWG | MAC | 0.60 NTU | 0.1 NTU |
| POD | Water | turbidity | For systems that use groundwater, turbidity should generally be below 1.0 NTU. Filtration systems should be designed and operated to reduce turbidity levels as low as reasonably achievable and strive to achieve a treated water turbidity target from individual filters of less than 0.1 NTU. | CDWG | AO/OG | 0.60 NTU | 0.1 NTU |
| | Water | turbidity | For systems that use groundwater, turbidity should generally be below 1.0 NTU. Filtration systems should be designed and operated to reduce turbidity levels as low as reasonably achievable and strive to achieve a treated water turbidity target from individual filters of less than 0.1 NTU. | CDWG | MAC | 0.60 NTU | 0.1 NTU |
| | Water | coliforms, thermotolerant [fecal] | The presence of E. coli indicates recent faecal contamination and the potential presence of microorganisms capable of causing gastrointestinal illnesses; pathogens in human and animal faeces pose the most immediate danger to public health. | CDWG | MAC | 1 CFU/100mL | 1 CFU/100mL |
| Seepage | Water | colour, true | May interfere with disinfection; removal is important to ensure effective treatment. | CDWG | AO/OG | 41.9 CU | 15 CU |



| SampleID/Client ID | Matrix | Analyte | Analyte Summary | Guideline | Category | Result | Limit |
|--------------------|--------|------------------|---|-----------|----------|-------------|-----------|
| | Water | turbidity | For systems that use groundwater, turbidity should generally be below 1.0 NTU. Filtration systems should be designed and operated to reduce turbidity levels as low as reasonably achievable and strive to achieve a treated water turbidity target from individual filters of less than 0.1 NTU. | CDWG | AO/OG | 26.3 NTU | 0.1 NTU |
| | Water | aluminum, total | There is no consistent, convincing evidence that aluminum in drinking water causes adverse health effects in humans. The operational guideline applies to treatment plants using aluminum-based coagulants; it does not apply to naturally occurring aluminum found in groundwater. For treatment plants using aluminum-based coagulants, monthly samples should be taken of the water leaving the plant; the OGs are based on a running annual average of monthly samples. | CDWG | AO/OG | 2.75 mg/L | 0.1 mg/L |
| | Water | iron, total | Based on taste and staining of laundry and plumbing fixtures; no evidence exists of dietary iron toxicity in the general population. | CDWG | AO/OG | 2.07 mg/L | 0.3 mg/L |
| | Water | manganese, total | Based on taste and staining of laundry and plumbing fixtures. | CDWG | AO/OG | 0.0716 mg/L | 0.02 mg/L |
| | Water | turbidity | For systems that use groundwater, turbidity should generally be below 1.0 NTU. Filtration systems should be designed and operated to reduce turbidity levels as low as reasonably achievable and strive to achieve a treated water turbidity target from individual filters of less than 0.1 NTU. | CDWG | MAC | 26.3 NTU | 0.1 NTU |



Summary of Guideline Limits

| Analyte | CAS Number | Unit | CDWG AO/OG | CDWG MAC | | | | | |
|---------------------------------------|------------|-----------|---------------|-------------|--|--|--|--|--|
| Physical Tests | | | | | | | | | |
| colour, true | ---- | CU | 15 CU | | | | | | |
| hardness (as CaCO3), from total Ca/Mg | ---- | mg/L | | | | | | | |
| turbidity | ---- | NTU | 0.1 NTU | 0.1 NTU | | | | | |
| Bacteriological Tests | | | | | | | | | |
| coliforms, thermotolerant [fecal] | ---- | CFU/100mL | | 1 CFU/100mL | | | | | |
| Total Metals | | | | | | | | | |
| aluminum, total | 7429-90-5 | mg/L | 0.1 mg/L | 2.9 mg/L | | | | | |
| antimony, total | 7440-36-0 | mg/L | | 0.006 mg/L | | | | | |
| arsenic, total | 7440-38-2 | mg/L | | 0.01 mg/L | | | | | |
| barium, total | 7440-39-3 | mg/L | | 2 mg/L | | | | | |
| beryllium, total | 7440-41-7 | mg/L | | | | | | | |
| bismuth, total | 7440-69-9 | mg/L | | | | | | | |
| boron, total | 7440-42-8 | mg/L | | 5 mg/L | | | | | |
| cadmium, total | 7440-43-9 | mg/L | | 0.007 mg/L | | | | | |
| calcium, total | 7440-70-2 | mg/L | | | | | | | |
| cesium, total | 7440-46-2 | mg/L | | | | | | | |
| chromium, total | 7440-47-3 | mg/L | | 0.05 mg/L | | | | | |
| cobalt, total | 7440-48-4 | mg/L | | | | | | | |
| copper, total | 7440-50-8 | mg/L | 1 mg/L | 2 mg/L | | | | | |
| iron, total | 7439-89-6 | mg/L | 0.3 mg/L | | | | | | |
| lead, total | 7439-92-1 | mg/L | | 0.005 mg/L | | | | | |
| lithium, total | 7439-93-2 | mg/L | | | | | | | |
| magnesium, total | 7439-95-4 | mg/L | | | | | | | |
| manganese, total | 7439-96-5 | mg/L | 0.02 mg/L | 0.12 mg/L | | | | | |
| mercury, total | 7439-97-6 | mg/L | | 0.001 mg/L | | | | | |
| molybdenum, total | 7439-98-7 | mg/L | | | | | | | |
| nickel, total | 7440-02-0 | mg/L | | | | | | | |
| phosphorus, total | 7723-14-0 | mg/L | | | | | | | |
| potassium, total | 7440-09-7 | mg/L | | | | | | | |
| rubidium, total | 7440-17-7 | mg/L | | | | | | | |
| selenium, total | 7782-49-2 | mg/L | | 0.05 mg/L | | | | | |
| silicon, total | 7440-21-3 | mg/L | | | | | | | |
| silver, total | 7440-22-4 | mg/L | | | | | | | |
| sodium, total | 17341-25-2 | mg/L | 200 mg/L | | | | | | |
| strontium, total | 7440-24-6 | mg/L | | 7 mg/L | | | | | |
| sulfur, total | 7704-34-9 | mg/L | | | | | | | |
| tellurium, total | 13494-80-9 | mg/L | | | | | | | |



| Analyte | CAS Number | Unit | CDWG AO/OG | CDWG MAC | | | | | |
|---------------------------------|------------|------|---------------|-------------|--|--|--|--|--|
| Total Metals - Continued | | | | | | | | | |
| thallium, total | 7440-28-0 | mg/L | | | | | | | |
| thorium, total | 7440-29-1 | mg/L | | | | | | | |
| tin, total | 7440-31-5 | mg/L | | | | | | | |
| titanium, total | 7440-32-6 | mg/L | | | | | | | |
| tungsten, total | 7440-33-7 | mg/L | | | | | | | |
| uranium, total | 7440-61-1 | mg/L | | 0.02 mg/L | | | | | |
| vanadium, total | 7440-62-2 | mg/L | | | | | | | |
| zinc, total | 7440-66-6 | mg/L | 5 mg/L | | | | | | |
| zirconium, total | 7440-67-7 | mg/L | | | | | | | |

Please refer to the General Comments section for an explanation of any qualifiers detected.

Key:

| | |
|-------|---|
| CDWG | Canada Guidelines for Canadian Drinking Water Quality (MAR, 2021) |
| AO/OG | Aesthetic Objective/Operational Guideline |
| MAC | Maximum Acceptable Concentrations |



www.alsglobal.com

Canada Toll Free: 1 800 668 9878

Chain of Custody (COC) / Analytical Request Form

COC Number: 20 - 933926

Page

of

Environmental Division
Kamloops
Work Order Reference
KS2103836



Telephone : + 1 250 372 3588

Report To: Contact and company name below will appear on the final report

Company: BC Timber Sales

Contact: Daniel Arcand

Phone: 250-819-7635

Street: 687 Yellowhead Hwy

City/Province: Clearwater, BC

Postal Code: V2E 1W2

Invoice To: Same as Report To

Company: BCIS

Contact: Daniel Arcand

ALS Account # / Quote #

Job #:

PO / AFE:

LSD:

ALS Lab Work Order # (ALS use only): KS2103836

Sample Identification and/or Coordinates (This description will appear on the report)

ALS Sample # (ALS use only)

Reports / Recipients

Select Report Format: PDF EXCEL EOD (DIGITAL)

Merge QC/QCI Reports with COA YES NO N/A

Compare Results to Criteria on Report - provide details below if box checked

Select Distribution: EMAIL MAIL FAX

Email 1 or Fax: daniel.arcand@gov.bc.ca

Email 2

Email 3

Select Invoice Distribution: EMAIL MAIL FAX

Email 1 or Fax: daniel.arcand@gov.bc.ca

Email 2

Invoice Recipients

Oil and Gas Required Fields (client use)

ATE/Cost Center:

Major/Minor Code:

Requisitioner:

Location:

ALS Contact:

Date (dd-mm-yy)

Time (hh:mm)

Sampler:

Sample Type

2-2-Nov-21 13:22

13:34

13:45

13:27

13:59

14:01

14:44

Notes / Specify Limits for result evaluation by selecting from drop-down below (Excel COC only)

Drinking Water (DW) Samples (client use)

Are samples taken from a Regulated DW System? YES NO

Are samples for human consumption/user? YES NO

Released by: SHIPMENT RELEASE (client use)

Turnaround Time (TAT) Requested

Routine [R] if received by 3pm M-F - no surcharges apply

4 day [P4] if received by 3pm M-F - 20% rush surcharge minimum

3 day [P3] if received by 3pm M-F - 25% rush surcharge minimum

2 day [P2] if received by 3pm M-F - 50% rush surcharge minimum

1 day [E] if received by 3pm M-F - 100% rush surcharge minimum

Same day [E2] if received by 10am M-S - 200% rush surcharge. Add may apply to rush requests on weekends, statutory holidays and non-

Date and Time Required for all E&P TATs:

For all tests with rush TATs requested, please

Indicate Filtered (F), Preserved (P) or Filtered &

Analysis R

NUMBER OF CONTAINERS

Metals

Fecal Coliform

Color

Turbidity

4

4

4

4

4

4

4

4

4

4

4

4

4

4

3

COOLING INITIATED

COOLING INITIATED

COOLING INITIATED


COOLING INITIATED

REFER TO BACK PAGE FOR ALS LOCATIONS AND SAMPLING INFORMATION

Failure to complete all portions of this form may delay analysis. Please fill in this form LEGIBLY. By the use of this form the user acknowledges and agrees with the Terms and Conditions as specified on the back page of the white - report copy.

WHITE - LABORATORY COPY YELLOW - CLIENT COPY

SHIPMENT RECEPTION (ALS use only) INITIAL SHIPMENT RECEPTION (ALS use only) FINAL SHIPMENT RECEPTION (ALS use only)



Avola Creek Watershed
305.5 Hectares

Roddy Creek Watershed
424.5 Hectares

- Channel Network
- Water License
- - - Licensed Works
- Roddy Watershed
- Avola Watershed
- Digital Elevation Model
- 1,955.697144
- 574.08429

0 1 2 3 km

1:50,000




Roddy Creek and Avola Creek Watershed Source Protection Study

Catchment Basins

NOTES:
LIDARBC LiDAR-1m ASCII Digital Elevation Grids processed into a terrain geotiffUsed to delineate regional watershed catchment basins

Drawn By: William Shulba, P.Geo
Date: July 2022

FIGURE 1



- Channel Network
- Water License
- Licensed Works
- Roddy Watershed
- Avola Watershed
- Digital Elevation Model
- 1,955.697144
- 574.08429

0 250 500 750 1,000 m

1:20,000




**Roddy Creek and Avola Creek Watershed
Source Protection Study**

Roddy Watershed Catchment

NOTES:
LIDARBC LiDAR-1m ASCII Digital Elevation Grids processed into a terrain geotiff Used to delineate regional watershed catchment basins

Drawn By: William Shulba, P.Geo
Date: July 2022

FIGURE 2



- Channel Network
- ◆ Water License
- - - Licensed Works
- Avola Watershed
- Roddy Watershed
- Digital Elevation Model
- 1,955.697144
- 574.08429

0 250 500 750 1,000 m

1:20,000




**Roddy Creek and Avola Creek Watershed
Source Protection Study**

**Avola Creek Watershed
Catchment**

NOTES:
LIDARBC LiDAR-1m ASCII Digital Elevation Grids processed into a terrain geotiff Used to delineate regional watershed catchment basins

Drawn By: William Shulba, P.Geo
Date: July 2022

FIGURE 3



- Channel Network
- Water License
- Licensed Works
- Roddy Watershed
- Avola Watershed
- Digital Elevation Model
- 1,955.697144
574.08429

0 50 100 150 200 m

1:5,000



**Roddy Creek and Avola Creek Watershed
Source Protection Study**

Water License F043942

NOTES:
LIDARBC LiDAR-1m ASCII Digital Elevation Grids processed into a terrain geotiff
Used to delineate regional watershed catchment basins

Drawn By: William Shulba, P.Geo
Date: July 2022

FIGURE 4